



DATE: March 29, 2004
TO: **Ex. 6 - Personal Privacy**
FROM: Jeff Smith
SUBJECT: Water Testing Results

Attached are the results of the water samples taken from your kitchen sink on March 23, 2004. The results indicate the level of nitrate (<1.0 milligram per liter) is below the drinking water standard of 10 milligrams per liter.

Paragraph 34 of the "Order on Consent" required Mountaire Farms to provide an emergency supply of drinking water until a permanent alternate water supply is installed. With the installation of the ion exchange unit and the results of this sampling showing the water to be compliant with drinking water standards, please be advised that Mountaire Farms will be discontinuing the supply of bottled water.

Please contact me at (302) 934-3094 so that the dispenser and remaining containers of water can be removed from your residence.

We appreciate your cooperation in this matter and as always, if you have any questions please do not hesitate to contact me at the number above.

Jeffrey Smith, REM
Environmental Manager



Mountaire Farms of Delaware, Inc.
P.O. Box 1320, Millsboro, Delaware 19966
(302) 934-1100 Toll Free (877) 887-1490

"We measure quality by how well we service our internal and external customers"



DATE: March 29, 2004
TO: **Ex. 6 - Personal Privacy**
FROM: Jeff Smith
SUBJECT: Water Testing Results

Attached are the results of the water samples taken from your kitchen sink on March 23, 2004. The results indicate the level of nitrate (1.48 milligram per liter) is below the drinking water standard of 10 milligrams per liter.

Paragraph 34 of the "Order on Consent" required Mountaire Farms to provide an emergency supply of drinking water until a permanent alternate water supply is installed. With the installation of the ion exchange unit and the results of this sampling showing the water to be compliant with drinking water standards, please be advised that Mountaire Farms will be discontinuing the supply of bottled water.

Please contact me at (302) 934-3094 so that the dispenser and remaining containers of water can be removed from your residence.

We appreciate your cooperation in this matter and as always, if you have any questions please do not hesitate to contact me at the number above.

A handwritten signature in black ink, appearing to read "Jeff Smith".

Jeffrey Smith, REM
Environmental Manager



Mountaire Farms of Delaware, Inc.
P.O. Box 1320, Millsboro, Delaware 19966
(302) 934-1100 Toll Free (877) 887-1490

"We measure quality by how well we service our internal and external customers"

03/25/04

Mountaire Poultry
P.O. Box 1320
Millsboro, DE 19966

Attention: Mr. Jeff Smith

Lab I.D.Description

13142D

Ex. 6 - Personal Privacy

 grab @ 0910-hrs on 3/23/04 by client:
received 3/23/04 by CMG of EI

<u>Parameter</u>	<u>Units</u>	<u>Results</u>	<u>Test Date</u>	<u>Time</u>	<u>Init</u>	<u>Method</u>
Nitrate as N	mg/L	< 1.0	03/24/04	950	EHK	4500D

Lab I.D.Description

13143D

Ex. 6 - Personal Privacy

 grab @ 0913-hrs on 3/23/04 by client:
received 3/23/04 by CMG of EI

<u>Parameter</u>	<u>Units</u>	<u>Results</u>	<u>Test Date</u>	<u>Time</u>	<u>Init</u>	<u>Method</u>
Nitrate as N	mg/L	1.48	03/24/04	950	EHK	4500D

Lab I.D.Description

13144D

Ex. 6 - Personal Privacy

 grab @ 0918-hrs on 3/23/04 by client:
received 3/23/04 by CMG of EI

<u>Parameter</u>	<u>Units</u>	<u>Results</u>	<u>Test Date</u>	<u>Time</u>	<u>Init</u>	<u>Method</u>
* Nitrate as N	mg/L	18.1	03/24/04	950	EHK	4500D

* Analyzed in duplicate with a relative standard deviation of +/- 4.93%

Ex. 6 - Personal Privacy

ENVIROCORP, INC.

CHAIN OF CUSTODY RECORD

Mountaire Poultry
P.O. Box 1320
Millsboro, Delaware 19966
Mr. Jeff Smith

LAB I.D.	TIME	DATE	DESCRIPTION	YES	NO	ANALYSES
1342D	9:00 AM	3-23-04	Sample #1 -	H2SO4		Nitrate
1	↓			Ice		Nitrite
2343D	9:13 AM		Sample #2 -	H2SO4		Nitrate
2	↓			Ice		Nitrite
344D	9:00		Sample #3 -	H2SO4		Nitrate
3	↓			Ice		Nitrite

RELINQUISHED BY:	DATE	TIME	RECEIVED BY:	COMMENTS
	3-23-04	10:05 AM		

Ex. 6 - Personal Privacy